



GES-6191

MULTIPLES OF SENSOR AMPERE RATING

<p>GENERAL ELECTRIC</p>	<p>INSULATED CASE CIRCUIT BREAKER POWER BREAK[®] Solid State</p>	<p>GES-6191</p>
<p>Sensor Rating 3000, 4000 amperes</p> <p>Voltage Rating 600 volts ac</p> <p>Frequency Rating 50/60 Hertz</p>	<p>With VersaTrip[®] MOD2</p> <p>Types TPSS, THSS Ground Fault Pickup Settings and Delay Time-current Curves <small>(Curves apply at 50/60 Hertz and from -20C to +55C breaker ambient)</small></p>	<p>Adjustments</p> <p>Ground Fault Unit: Pick-up current settings are 0.20X, 0.22X, 0.25X, 0.30X, 0.35X and 0.40X for 3000A sensor rating, and 0.18X, 0.20X, 0.22X, 0.25X, 0.27X and 0.30X for 4000A sensor rating. Time-delay bands are maximum, intermediate, and minimum.</p>