



GENERAL ELECTRIC

Current Ratings
 15, 20 and 30 Amperes TXQL, TXQB & TXQC
 15, 20, 30, 40 and 50 Amperes

Voltage Ratings
 1 and 2 Pole—120/240 Volts, A-c
 2 and 3 Pole—240 Volts, A-c

Frequency Rating
 60 Cycles

MOLDED-CASE CIRCUIT BREAKER
"Q" LINE
AMBIENT COMPENSATED

Types TQL-AC (2 & 3 Pole), TXQB, TXQC & TXQL (1 & 2 Pole)
TQB, THQB, TQC, THQC and THQL-AC (1, 2 & 3 Pole)
Long-time Delay and Instantaneous
Time-current Curve

(Curves show circuit breaker in open air, 10-50C ambient, wired with conductors of corresponding rating, no prior load. For all other ambients use rating shift index at top of sheet.)

K215-63C

Adjustments

Long-time delay thermal trip: not adjustable
 Instantaneous magnetic trip: not adjustable