



<p>GENERAL ELECTRIC</p> <p>Current Ratings 2 and 3 Pole—60, 70, 90 and 100 Amperes 1 Pole—60 and 70 Amperes</p> <p>Voltage Ratings 1 and 2 Pole—120/240 Volts, A-c 2 and 3 Pole—240 Volts, A-c</p> <p>Frequency Rating 60 Cycles</p>	<p>MOLDED-CASE CIRCUIT BREAKER</p> <p>"Q" LINE</p> <p>AMBIENT COMPENSATED</p> <p>Types TQAL-AC, THQAL-AC, TQB, THQB, TQC & THQC</p> <p>Long-time Delay and Instantaneous Time-current Curve</p> <p>(Curves show circuit breaker in open air, 10-50°C ambient, wired with conductors of corresponding rating, no prior load. For all other ambients use rating shift index at top of sheet.)</p>	<p>K215-64C</p> <p>Adjustments</p> <p>Long-time delay thermal trip: not adjustable Instantaneous magnetic trip: not adjustable</p>
---	---	---

Rev. 1-18-58

CIRCUIT PROTECTIVE DEVICES DEPARTMENT PLAINVILLE, CONNECTICUT