



MULTIPLES OF CURRENT RATING



TYPE AK LOW-VOLTAGE POWER CIRCUIT BREAKER  
**EC-1B SERIES TRIP DEVICE**

GES-6003

Current Ratings (Amperes)

AK-75                    2000, 2500, 3000  
 AK-100                 2000, 2500, 3000, 4000

**1BB-3 Long-time-delay and Instantaneous  
 Time-current Curves**

(Curves apply at 60 cycles for ambient temperature of 25 C)

Adjustments

Long-time-delay Unit: Pickup settings are 80 to 160% of rating. (Settings higher than 100% do not increase the continuous current rating.)  
 Instantaneous Unit: Pickup settings are 4 to 9X, or 6 to 12X (std.), or 9 to 15X of rating.